



## ASTM E-84 Results:

### Forestree Wood Veneer Wallcovering

Product	Flame Spread	Smoke Developed Index	Rating
Natural Veneer *	15	5	Class A
Reconstituted Veneer **	15	25	Class A

\* Natural Veneer marketed as Classic Wood

\*\* Reconstituted Veneer marketed as Friendly Forest

### ASTM E-84 Ratings Explanation

In order to obtain the Flame Spread Classification, results must fall into the ranges below.

Rating	Flame Spread	Smoke Developed Index
<b>Class A</b>	<b>0 - 25</b>	<b>&lt; 450</b>
Class B	30 - 75	< 450
Class C	80 - 200	< 450